

IMPORTANT DRINKING WATER DEFINITIONS

MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

PDWS: Primary Drinking Water Standards: MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

PHG: Primary Health Goal: The level of contaminant in drinking water below below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

MRDLG: Maximum Residual Disinfection Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MRDL: Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MNR: Monitored Not Regulated

MPL: Maximum Permissible Level as determined by the state of California

SOUTH TAHOE PUBLIC UTILITY DISTRICT
1275 Meadow Crest Drive
South Lake Tahoe, CA 96150

FOR MORE INFORMATION PLEASE CONTACT:
Dennis Cocking,
District Information Officer

Phone 530-544-6474
Fax 530-541-0614
Email dcocking@stpud.dst.ca.us
Website www.stpud.us

HOW CAN I GET INVOLVED? The information contained in the Consumer Confidence Report may not answer all the questions you may have about the quality of the South Tahoe Public Utility District’s drinking water supply. The District welcomes public participation in developing water quality and quantity policy. For more information, please call the District Information Office at 530-544-6474 extension 6208. If you would like more detailed scientific information, please call the District Laboratory at 530-544-6474 extension 6231, or check our website at www.stpud.us

The District is governed by an elected five-member Board of Directors. Board meetings are held on the first and third Thursday of each month at 2:00 p.m. at the Customer Service Facility located at 1275 Meadow Crest Drive. All meetings are open to the public and the District encourages our customers to attend and become involved in the policy making process.

RESULTS OF RADON MONITORING Radon is a radioactive gas that you can’t see, taste or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will, in most cases, be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. Fix your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that aren’t too costly. For additional information,

call your state radon program or call EPA’s Radon Hotline (800-SOS-RADON).

RESULTS OF VOLUNTARY MONITORING See data sheets.

REGARDING ARSENIC Arsenic is a naturally occurring substance that is sometimes found at very low levels in drinking water, primarily groundwater. The U.S. Environmental Protection Agency (EPA) was required by the Safe Drinking Water Act Amendments of 1996 to finalize a new drinking water standard for arsenic in 2001 based on good scientific information and data.

In September 2001, EPA adopted a new arsenic standard, or maximum contaminant level (MCL), of 0.010 milligrams per liter or 10 parts per billion (PPB). This new standard went into effect on January 23, 2006. Water utilities were not immediately declared out of compliance or in violation of the new standard. The federal regulation requires that water systems monitor for arsenic during the first 1-3 years to determine their official compliance levels. The District completed that monitoring in 2008.

Since the California Department of Public Health (DPH) remains at the prior MCL of 50 PPB, the federal standard of 10 PPB is in effect in California. DPH is helping EPA to implement the federal standard, but EPA is in charge of enforcing it. When California finalizes its standard, DPH will resume enforcement duties as well.

Of the District’s fourteen active drinking water wells, two exceeded the new standard. Of those two wells, one has been disconnected from the water distribution system, but could be placed into service in the event of an emergency, such as wildfire. On the remaining well, a DPH-approved treatment facility has been operational since October 2009. The District is in full compliance with both state and federal standards.

Presorted
Standard Mail
U.S. Postage **Paid**
Mailed from Zip
Code 92899
Permit #146

CONSUMER CONFIDENCE REPORT 2010

SPANISH (ESPAÑOL)
Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.



UNIT DESCRIPTIONS

ug/L: Parts per billion

mg/L: Number of milligrams of substance in one liter of water

ppm: Parts per million, or milligrams per liter (mg/L)

ppb: Parts per billion, or micrograms per liter (µg/L)

ppt: Parts per trillion, or nanograms per liter

ppq: Parts per quadrillion, or picograms per liter

pCi/L: Picocuries per liter (a measure of radioactivity)

mrem/yr: Millirems per year (a measure of radiation absorbed by the body)

MFL: Million Fibers per Liter, used to measure asbestos concentration

NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

positive samples/month: The number of samples taken monthly that were found to be positive

positive samples/yr: The number of positive samples taken that year

% positive samples/month: Percentage of samples taken monthly that were positive

% killed or inactivated: Percentage of viruses/bacteria killed or inactivated by treatment method

CFU/ml: Colony Forming Units per milliliter

NA: Not Applicable

ND: Not Detected

NR: Not Required, but recommended

WATER QUALITY DATA TABLE

The table to the right lists all of the drinking water contaminants that we detected that are applicable for the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

ADDITIONAL CONTAMINANTS

In an effort to insure the safest water possible the State has required us to monitor some contaminants not required by Federal regulations. Of those contaminants only the ones listed to the right were found in your water.

IS MY WATER SAFE? Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. The South Tahoe Public Utility District vigilantly safeguards its water supplies and, once again, we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

DO I NEED TO TAKE SPECIAL PRECAUTIONS? Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA’s Safe Water Drinking Hotline (1-800-426-4791).

WHERE DOES MY WATER COME FROM? The District’s service area is organized into 16 pressure zones serving over 2.4 billion gallons annually from 14 active drinking water wells to nearly 14,000 homes and businesses. All our drinking water is pumped from underground aquifers. No water is taken from Lake Tahoe or any other surface water source.

SOURCE WATER ASSESSMENT AND ITS AVAILABILITY

The District has an ongoing drinking water source development program to seek potential drinking water well locations. Due to the volume of the average annual Sierra snowpack and Lake Tahoe itself, our aquifer has a significant recharge capability. The District continues to work diligently to protect and maintain this precious natural resource.

CONTAMINANTS	MCLG/PHG OR MRDLG	MCL OR MRDL OR NL	AVG	RANGE LOW	HIGH	SAMPLE DATE	VIOLATION	TYPICAL SOURCE
INORGANIC CONTAMINANTS								
Aluminum (ppb)	600	1,000	20	ND	21	2010	No	
Arsenic (ppb)	0.004	10	3.6	ND	9.0	2010	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppb)	2,000	1,000	10	ND	33	2010	No	Erosion of natural deposits
Chromium (ppb)		50	1.1	ND	1.4	2010	No	Erosion of natural deposits
Fluoride (ppm)	1	2	0.08	ND	0.22	2010	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	0.26	0.03	0.90	2010	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (optional) (ppb)	NA	MPL	11.8	4.4	25.0	2010	No	Erosion of natural deposits; Leaching
RADIOACTIVE CONTAMINANTS								
Gross Alpha (pCi/L), minus Uranium		15	1.92	0.24	5.13	2010	No	Erosion of natural deposits
Uranium (pCi/L)	0.5	20	5.05	1.38	12.9	2010	No	Erosion of natural deposits
Radium-226 (pCi/L)	0.05		0.27	0.02	0.93	2010	No	Erosion of natural deposits
Radium-228 (pCi/L)	0.019		1.03	0.44	1.97	2010	No	Erosion of natural deposits
Radium-226 + Radium-228		5	1.30	0.70	1.99	2010	No	Erosion of natural deposits
VOLATILE ORGANIC CONTAMINANTS								
MTBE [Methyl Tert Butyl Ether] (ppb)	5	13	ND	ND	0.37	2010	No	Leaking underground fuel storage tanks
THHMs [Total Trihalomethanes] (ppb)	NA	80	1.6	ND	4.3	2010	No	Byproduct of drinking water disinfection
HaloAcetic Acids	NA	60	0.3	ND	1.4	2010	No	Byproduct of drinking water disinfection
MICROBIOLOGICAL CONTAMINANTS								
Total Coliforms (% Positive each month)		5	0	0	0	2010	No	
E. Coli (% Positive)		0	0	0	0	2010	No	
Heterotrophic Plate Count or HPC (CFU)		NA	0.7	ND	22.3	2010	No	
Turbidity (NTU) The Turbidity limit for the highest single measurement.		5	0.26	0.02	0.73	2010		Soil runoff

INORGANIC CONTAMINANTS	MCLG/PHG	AL	90TH PERCENTILE	SAMPLE DATE	# SAMPLES EXCEEDING AL	EXCEEDS AL	TYPICAL SOURCE
Lead - action level at consumer taps (ppb)	ND	15	ND	2008	0	No	Corosion of household plumbing systems; Erosion of natural deposits
Copper - action level at consumer taps (ppb)	ND	1,300	110	2008	0	No	Internal corosion of household plumbing systems; erosion of natural deposits;leaching from wood preservatives

CONTAMINANT	STATE MCL	AVG	VIOLATION	SAMPLE DATE	EXPLANATION AND COMMENT
Alkalinity,Total (ppm)	NA	52.1 mg/L	No	2010	Erosion of natural deposits
Bromide (ppm)	NA	0.014 mg/L	No	2010	Erosion of natural deposits
Calcium (ppm)	NA	12.4 mg/L	No	2010	Erosion of natural deposits
Carbon Dioxide, Free (ppm)	NA	6.9 mg/L	No	2010	Naturally occuring
Chloride (ppm)	500	8.4 mg/L	No	2010	Erosion of natural deposits
Chlorine, Free (ppm)	4 mg/L	0.48 mg/L	No	2010	Byproduct of disinfection process
Color (Units)	15	ND	No	2010	Naturally occurring organic materials
Copper (ppm)	NA	4	No	2010	
Dissolved Solids, Total (ppm)	1,000 mg/L	95 mg/L	No	2010	Erosion of natural deposits
Electrical Conductance (umhos/cm)	1,600	142	No	2010	Erosion of natural deposits
Hardness (ppm)	NA	41.9 mg/L	No	2010	Erosion of natural deposits
Iron (ppb)	300	21 ug/L	No	2010	Erosion of natural deposits
Magnesium (ppm)	NA	2.47 mg/L	No	2010	Erosion of natural deposits
Manganese (ppm)	50	3	No	2010	
OdorThreshold (Units)	3	1	No	2010	Naturally occurring organic materials
Organic Carbon, Total (ppm)	NA	0.32 mg/L	No	2010	
orthoPhosphate, as P (ppm)	NA	0.034 mg/L	No	2010	Erosion of natural deposits
Phosphorus, Total (ppm)	NA	0.045 mg/L	No	2010	Erosion of natural deposits
pH	NA	7.95 Units	No	2010	Erosion of natural deposits
Potassium (ppm)	NA	1.37 mg/L	No	2010	Erosion of natural deposits
Radon pCi/L)	NA	981 pCi/L	No	2010	
Sulfate (ppm)	500	3.68 mg/L	No	2010	Erosion of natural deposits
Temperature - System (°F)	NA	50°	No	2010	Erosion of natural deposits
Vanadium (ppb)	NA	3.6	No	2010	Erosion of natural deposits
Zinc (ppb)	5,000	ND	No	2010	