



A guide to help you determine the appropriate number of sewer units for your home or business

The following is a schedule for the appropriate number of sewer connections to be applied to the variety of connections the District's sewer collection system affords.

Homes and Apartments: A minimum of three (3) connections for each home or each apartment and one (1) additional connection for each bath or half-bath in excess of two (2) baths, except that a studio apartment shall be two (2) sewer connections



Motels: Each bath, one (1) connection; each kitchen or kitchenette, one (1) connection

Restaurant: One (1) connection per restroom; five (5) connections for the first twenty (20) seats, and one (1) additional connection for every twenty (20) seats or fraction thereof more than twenty (20). For the purpose of this section, where a bar is operated in connection with the restaurant, bar stools will be counted as seats. Snack premises will be counted as other commercial in a subparagraph.

Fuel Station: Five (5) connections, one (1) connection per RV sewer dump

Trailer/RV Parks: three (3) connections per trailer/RV space that will accommodate a trailer of 40 feet with a sewer connection provided; one (1) connection per trailer/RV space for all other trailer/RV spaces with a sewer connection provided. One (1) connection per two (2) trailer spaces without a sewer connection provided.

Laundromats: Two (2) connections per machine

Swimming Pools/Commercial Hot Tubs Two (2) connections

Automobile Service Garage: Two (2) connections plus one (1) connection for each restroom

Taverns without food facilities: Five (5) connections, and one (1) connection for each restroom

All other commercial establishments: One (1) connection per five (5) fixture connections as defined in the Uniform Plumbing Code (UPC)

Special Charges

Facilities in or about residential and industrial establishments discharging an extraordinary amount of waste into the sewage collection system will be subject to such charges and to such conditions as may be set by the Board of Directors.

Please remember, it is the duty of the sewer service user to report any increase or decrease of sewer connections serving your property.

Should you have any questions regarding the above information, please contact the Customer Service



Fixture	Number of Fixture Units	
	Private Use	Public Use
Bar Sink	1	2
Bathtub (w/or wo shower)	2	2
Drinking Fountain	0.5	0.5
Floor Sink/Drain	2	2
Laundry Tub	2	2
Mop Sink	2	3
Lavatory	1	1
Shower (Per Head)	2	2
Dishwasher	2	2
Wash up sink	2	2
Urinal	2	2
Water Closet	3	4

▶ **South Tahoe Public Utility District**

Customer Service Department
1275 Meadow Crest Drive
South Lake Tahoe CA 96150

Phone: 530-544-6474
Fax: 530-541-0614
E-mail: cs@stpuddst.ca.us

