



## SCHEDULE OF SEWER CONNECTIONS

### A guide to help you determine the appropriate number of sewer units for your home or business

The following is a schedule for the appropriate number of sewer connections to be applied to the variety of connections the District's sewer collection system affords.

**Homes and Apartments:** A minimum of three (3) connections for each home or each apartment and one (1) additional connection for each bath or half-bath in excess of two (2) baths, except that a studio apartment shall be two (2) sewer connections



**Motels:** Each bath, one (1) connection; each kitchen or kitchenette, one (1) connection

**Restaurant:** One (1) connection per restroom; five (5) connections for the first twenty (20) seats, and one (1) additional connection for every twenty (20) seats or fraction thereof more than twenty (20). For the purpose of this section, where a bar is operated in connection with the restaurant, bar stools will be counted as seats.

**Fuel Station:** Five (5) connections, one (1) connection per RV sewer dump

**Trailer/RV Parks:** three (3) connections per trailer/RV space that will accommodate a trailer in excess of 40 feet with a sewer connection provided; one (1) connection per trailer/RV space for all other trailer/RV spaces with a sewer connection provided. One (1) connection per two (2) trailer spaces without a sewer connection provided.

**Swimming Pools:** Two (2) connections

**Automobile Service Garage:** Two (2) connections plus one (1) connection for each restroom

**Taverns without food facilities:** Five (5) connections, and one (1) connection for each restroom

**All other commercial establishments:** One (1) connection per five (5) fixture units as defined in the UPC

## Special Charges

Facilities in or about residential and industrial establishments discharging an extraordinary amount of waste into the sewage collection system will be subject to such charges and to such conditions as may be set by the Board of Directors.

The District's current rate for sewer service is available online on the District's Web Page at [www.stpud.us](http://www.stpud.us).

If you have any questions regarding the above information, please contact Customer Service at 530-544-6474.



# SCHEDULE OF SEWER CONNECTIONS

| Fixture                   | Number of Fixture Units |            |
|---------------------------|-------------------------|------------|
|                           | Private Use             | Public Use |
| Bar Sink                  | 1                       | 2          |
| Bathtub (w/or Wo shower)  | 4                       | 4          |
| Drinking Fountain         | 0.5                     | 0.5        |
| Floor Sink                | 2                       | 2          |
| Laundry Tub               | 1.5                     | 1.5        |
| Mop Sink                  | 1.5                     | 3          |
| Lavatory                  | 1                       | 1          |
| Shower (Per Head)         | 2                       | 2          |
| Dishwasher                | 1.5                     | 1.5        |
| Wash up sink              | 2                       | 2          |
| Urinal                    | 2                       | 2          |
| Water Closet              | 2.5                     | 2.5        |
| Commercial Clothes Washer | 3                       | 3          |

▶ **South Tahoe Public Utility District**

Customer Service Department  
 1275 Meadow Crest Drive  
 South Lake Tahoe CA 96150

Phone: 530-544-6474  
 Fax: 530-541-0614  
 E-mail: [cs@stpud.us](mailto:cs@stpud.us)

